


IG200C

INDUSTRIAL RANGE
POWER BY CUMMINS

IGNT



POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

STANDARD USAGE CONDITIONS:

1. Altitude: below 1000 meters;
2. Environmental temperature: 25 °C
3. Relative humidity: 30%

ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual.

The noise value we provide is based on

QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:
ISO 1400:2015 Environmental System;
ISO 45001:2018 Safty System;
ISO 9001:2015 Quality System

SERVICE		PRP	ESP
Power	KVA	181	200
Power	KW	145	160
standard voltage	V	400/230	
available voltage	V	380/220 415/240	
Rated Current	A	262	
frequency/speed	hz/rpm	50/1500	

Weight and Dimension

Dimension		Open	Silent
Length (L)	mm	2400	3290
Width (W)	mm	950	1130
Height (H)	mm	1560	1850
Net Weight	KG	1680	2280
Fuel Tank	L	360	

IG200C

INDUSTRIAL RANGE
POWER BY CUMMINS

IGNT

Engine Specifications

General Engine Data-- Cummins		
Engine Model		6CTA8.3-G1
Piston Speed	m/s	6.8
Fuel Injection		BYC A
No. of Cylinders		6
Displacement	L	8.3
Bore* Stroke	mm	114*135
Compression Ratio		17.3
Rated Net Power	KW	145
Governor Type		M
Base Output	kw	163

Air intake system		
Maximum intake air restriction with heavy duty air cleaner:		
Air Intake Flow	L/s	192

Lubrication System		
Low idle	kPa	103
Rated speed	kPa	276-414
Max. oil temperature	°C	121

Alternator Specifications

Alternator Data-- IGNT		
Alternator Model		IA274G
Phase		3
Voltage	V	400
Prime Power	KVA	181
Pole		4
Excitation System		Self-excited, Brushless
No. of Bearing		1
Power Factor		0.8
Wiring Connection		3 Phases, 4 Wires
Insulation Grade		H/H
Protection Grade		IP23
Voltage Regulation	%	±0.5

Fuel System		
Fuel Consumption @110% ESP	L/h	48
Fuel Consumption @100% PRP	L/h	42
Fuel Consumption @75% PRP	L/h	31
Fuel Consumption @50% PRP	L/h	21
Total Drain Flow	L/h	193
Fuel Tank Capacity (Silent)	L	/

Starter System		
Start Motor Voltage	V	24
No. of Batteries		2

Cooling System		
Engine Coolant Capacity	L	12.3
Thermostat Operating Range	°C	82 - 95
Max. coolant cycling	kPa	28
Min. Pressure Cap	kPa	69

Exhaust System		
Max. Exhaust Temp.	°C	/
Exhaust Flow	L/s	521
Max. Back Pressure	kPa	10

Alternator Data-- Stamford		
Alternator Model		UCI274G
Phase		3
Voltage	V	400
Prime Power	KVA	181
Pole		3
Excitation System		Self-excited, Brushless
No. of Bearing		3
Power Factor		0.8
Wiring Connection		3 Phases, 4 Wires
Insulation Grade		H/H
Protection Grade		IP23
Voltage Regulation	%	±0.5

Controller Specifications

Control Panel Date-- Deepsea DSE6120

- Built in PLC logic programming
- Generator voltage detection
- Mains voltage detection
- Generator/load power detection (kW, kVA, kVAr, p
- Generator overload protection (kW)
- Equipped with manual closing and opening functio
- Start gen-set when the battery voltage is low
- LCD and LED alarm indication
- Generator/load current monitoring and protection
- Fuel pump control function
- Can connect to all expansion modules
- Capable of graded loading
- Engine speed protection
- Engine preheating
- Engine starts rapidly&stops rapidly
- Custom remote start signal

Generator Specifications

Standard Configuration

- 50°C radiator for belt driven fan
- 12/24V charging alternator
- One set of air/fuel/oil filters
- Chassis with integrated fuel tank
- Emergency stop button
- Anti-vibration shock absorbers
- Main circuit breaker/ MCCB
- Auto control system
- User manual

Optional Configuration

- Battery charger
- Engine pre-heater
- Alternator pre-heater
- PMG/ AREP/ MAUX
- Water-oil separator
- Inside automatic transfer switch/ ATS box
- Grounding copper rod
- Remote control system
- Switch box

Warranty of Generator Set

Cummins Engine

One year or 1000 running hours whichever comes first

Generator

One year or 1000 running hours whichever comes first





