

### POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

#### STANDARD USAGE CONDITIONS:

Altitude: below 1000 meters;
 Environmental temperature: 25 °C

2. Environmental temperature. 20 C

3. Relative humidity: 30%

### ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual. The noise value we provide is based on laboratory testing and is for reference.

### QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:

ISO 1400:2015 Environmental System;

ISO 45001:2018 Safty System; ISO 9001:2015 Quality System

SERVICE		PRP	ESP
Power	KVA	2000	2200
Power	KW	1600	1760
Standard Voltage	V	400/230	
Available Voltage	V	380/220	415/240
Rated Current	A	28	387
Frequency/Speed	HZ/RPM	50/	1500

## Weight and Dimension

	Dimension	ı	0pen	Silent
Length	(L)	mm	6200	12192
Width	( W)	mm	2850	2438
Height	(H)	mm	3290	2591
Net Weigh	t	KG		
Fuel Tank		L		

# **IG2200M**

# INDUSTRIAL RANGE POWER BY CUMMINS



# Engine Specifications

General Engine Date -	- CUMMINS CCEC
Engine Model	S16R-PTAA2-C
Configuration	VEE type
Working Mode	Turbocharged and Aftercooled
No. of Cylinders	16
Displacement (L)	65. 37
Bore* Stroke (mm)	170*180
Compression Ratio	14:01
Rated Net Power(KW)	1600
Rated Power	1684kw

L/h	/
L/h	404
L/h	313
L/h	217
L	/
L	/
	L/h L/h

Starter System		
Start Motor Voltage	V	24
No. of Batteries	2	)

Air intake system		
Intake air flow	L/s	/
Cooling air flow	L/s	/
Air Filter	/	′

Cooling System		
Coolant capacity-engine only	L	/
Thermostat adjusting temperature	$^{\circ}\mathbb{C}$	/
Max.coolant cycling resistance exterior	engine	/
Min. Pressure Cap	kPa	/

Lubrication System	1	
Lube Oil Capacity	L	200
Lubrication System	Splash	Lubrication
Rated speed	kPa	/

Exhaust system		
Max. exhaust temperature	${\mathbb C}$	/
Exhaust gas flow	L/s	/
Max. allowed back pressure	kPa	/

## Alternator Specifications

Alternator Date	· IGNT	
Alternator Model		IA734F
Phase		3
Voltage (V)		400
Prime Power (KW)		1600
Pole		4
Excitation System	lf-excited,	Brushless
No. of Bearing		1
Power Factor		0.8
Wiring Connection	3 Phases,	4 Wires
Insulation Grade		H/H
Protection Grade		IP23
Voltage Regulation (%)		$\pm 0.5$

Alternator Date	Stamford	1
Alternator Model		S7L1D-G4
Phase		3
Voltage	V	400
Prime Power	KW	1600
Pole		4
Excitation System		elf-excited, Brushles
No. of Bearing		3
Power Factor		0.8
Wiring Connection		3 Phases, 4 Wires
Insulation Grade		H/H
Protection Grade		IP23
Voltage Regulation	%	$\pm 0.5$

# **IG2200M**

# INDUSTRIAL RANGE POWER BY CUMMINS



## Controller Specifications

Transfer of the second of the	
Control Panel Date Deepsea DSE6120	
<ul> <li>Built in PLC logic programming</li> </ul>	• Generator/load current monitoring and protection
• Generator voltage detection	• Fuel pump control function
<ul><li>Mains voltage detection</li></ul>	• Can connect to all expansion modules
● Generator/load power detection (kW, kVA, kVAr, pf)	• Capable of graded loading
● Generator overload protection (kW)	<ul><li>Engine speed protection</li></ul>
• Equipped with manual closing and opening functions	<ul><li>Engine preheating</li></ul>
• Start gen-set when the battery voltage is low	<ul><li>Engine starts rapidly&amp;stops rapidly</li></ul>
<ul> <li>LCD and LED alarm indication</li> </ul>	Oustom remote start signal

## Generator Specifications

Standard Configuration	Optional Configuration
● 50°C radiator for belt driven fan	<ul> <li>Battery charger</li> </ul>
● 12/24V charging alternator	● Engine pre-heater
• One set of air/fuel/oil fiters	<ul><li>Alternator pre-heater</li></ul>
• Chassis with integrated fuel tank	● PMG/ AREP/ MAUX
<ul><li>Emergency stop button</li></ul>	● Water-oil seperator
● Anti-vibration shock absorbers	● Inside automatic transfer switch/ ATS box
● Main circuit breaker/ MCCB	<ul> <li>Grounding cooper rod</li> </ul>
• Auto control system	● Remote control system
• User manual	Switch box

### Warranty of Generator Set

Cummins Engine

One year or 1000 running hours whichever comes first

Generator

One year or 1000 running hours whichever comes first

Email: ignt@igntpower.com Web: www.igntpower.com